SUDAS Revision Submittal Form

Status Date:	As of 5/12/2017	Topic:	PVC water main pipe
Manual:	Specifications	Manual Location:	Section 5010, 2.01, A

Requested Revision:

2.01 WATER MAIN

- **A.** Polyvinyl Chloride (PVC) Pipe: Comply with AWWA C900 or AWWA C905 with gray iron pipe equivalent outside diameters.
 - 1. Minimum Wall Thickness:
 - a. 4 inch through 24 inch sizes: DR 18.
 - **b.** Sizes over 24 inch: As specified in the contract documents.
 - **2. Joint Type:** Use push-on joint type, except as otherwise specified in the contract documents or as authorized by the Engineer.
 - a. Push-on: According to AWWA C900 or AWWA C905.
 - **b. Integral Restrained Joint:** AWWA C900 or AWWA C905 pipe with restraining system manufactured integrally into pipe end.
 - c. Mechanical Restrained Joint: Ductile iron mechanical device designed for joint restraint of AWWA C900 or AWWA C905 pipe complying with the requirements of ASTM F 1674.
 - 3. Markings on Pipe:
 - a. Name of manufacturer.
 - b. Size and class.
 - c. Spigot insertion depth gauge.
 - d. National Sanitation Foundation (NSF) seal.

Reason for Revision: Deleted references to AWWA C905 due to combining of AWWA C900 and C905.

Comments: None.

District:					
Comments:	None.				
Action:	Deferred	☐ Not Approved			
District:		□ 4 □ 5 □ 6			
Comments:	None.				
Action:	☐ Deferred	☐ Not Approved			
District:	□ 1 □ 2 □ 3	□ 4 □ 5 □ 6			
Comments:	None.				
Action:	Deferred	☐ Not Approved			
District:	□ 1	□ 4 □ 5 □ 6			
Comments:	None.				
Action:	☐ Deferred	☐ Not Approved			
District:	□ 1 □ 2 □ 3	□ 4 □ 5 ⋈ 6			
Comments:	None.				
Action:	☐ Deferred	☐ Not Approved			
District:	□ 1 □ 2 □ 3	□ 4			
Comments:	None.				
Action:	☐ Deferred	☐ Not Approved			
Final District Action Summary: All 6 districts approved.					
Board of Directors Action: Approved.					