

SUDAS Revision Submittal Form

Status Date: As of 5/12/2017 **Topic:** Sidewalk consolidation
Manual: Specifications **Manual Location:** Section 7030, 3.04, B

Requested Revision:

3.04 PCC SIDEWALKS, SHARED USE PATHS, AND DRIVEWAYS

B. Concrete Pavement Placement:

1. **Shared Use Paths:** Comply with Section 7010.
2. **Sidewalk:**
 - a. Maintain moist subgrade in front of paving operation
 - b. Deposit concrete on the subgrade as required to minimize rehandling to prevent segregation.
 - c. Hand spread with shovels, not rakes.
 - d. Place concrete as required to slightly overfill the space between the forms.
 - e. ~~Consolidate with vibrators and s~~ For thicknesses less than 5 inches, consolidate by knifing with hand tools. When thickness is 5 inches or greater, consolidate with hand or mechanical vibrators meeting 7010, 3.01, B, 3. Smooth by use of a straightedge.
 - f. Do not contaminate freshly mixed concrete with earth or other foreign materials.
3. **Driveways:** Comply with Figures 7030.101 and 7030.102 and Section 7010. The use of a paving machine is not required.

Reason for Revision: Clarify that sidewalk thickness less than 5 inches do not require use of a vibrator.

Comments: None.

District:	<input type="checkbox"/> 1	<input type="checkbox"/> 2	<input type="checkbox"/> 3	<input checked="" type="checkbox"/> 4	<input type="checkbox"/> 5	<input type="checkbox"/> 6
Comments:	None.					
Action:	<input type="checkbox"/> Deferred		<input type="checkbox"/> Not Approved		<input checked="" type="checkbox"/> Approved	
District:	<input type="checkbox"/> 1	<input type="checkbox"/> 2	<input checked="" type="checkbox"/> 3	<input type="checkbox"/> 4	<input type="checkbox"/> 5	<input type="checkbox"/> 6
Comments:	None.					
Action:	<input type="checkbox"/> Deferred		<input type="checkbox"/> Not Approved		<input checked="" type="checkbox"/> Approved	
District:	<input checked="" type="checkbox"/> 1	<input type="checkbox"/> 2	<input type="checkbox"/> 3	<input type="checkbox"/> 4	<input type="checkbox"/> 5	<input type="checkbox"/> 6
Comments:	Change the first [new] sentence to less than 5 inches; change the second [new] sentence to 5 inches or greater. <i>Note - done.</i>					
Action:	<input type="checkbox"/> Deferred		<input type="checkbox"/> Not Approved		<input checked="" type="checkbox"/> Approved	
District:	<input type="checkbox"/> 1	<input checked="" type="checkbox"/> 2	<input type="checkbox"/> 3	<input type="checkbox"/> 4	<input type="checkbox"/> 5	<input type="checkbox"/> 6
Comments:	Agreed with District 1's suggestions; also add "mechanical" to the second [new] sentence. <i>Note - done.</i>					
Action:	<input type="checkbox"/> Deferred		<input type="checkbox"/> Not Approved		<input checked="" type="checkbox"/> Approved	
District:	<input type="checkbox"/> 1	<input type="checkbox"/> 2	<input type="checkbox"/> 3	<input type="checkbox"/> 4	<input type="checkbox"/> 5	<input checked="" type="checkbox"/> 6
Comments:	None.					
Action:	<input type="checkbox"/> Deferred		<input type="checkbox"/> Not Approved		<input checked="" type="checkbox"/> Approved	
District:	<input type="checkbox"/> 1	<input type="checkbox"/> 2	<input type="checkbox"/> 3	<input type="checkbox"/> 4	<input checked="" type="checkbox"/> 5	<input type="checkbox"/> 6
Comments:	None.					
Action:	<input type="checkbox"/> Deferred		<input type="checkbox"/> Not Approved		<input checked="" type="checkbox"/> Approved	

Final District Action Summary: All 6 districts approved; see comments above.

Board of Directors Action: Approved.