

## SUDAS Revision Submittal Form

**Status Date:** As of 5/20/2025 **Topic:** Pipe size for closed profile PVC pipe  
**Manual:** Specifications **Manual Location:** Section 4010, 2.01, D

---

### Requested Revision:

#### 2.01 SANITARY SEWER (Gravity Mains)

...

#### D. Closed Profile Polyvinyl Chloride Pipe (PVC) 21 inch to ~~36~~ 60 inch:

1. Comply with ASTM F 1803.
2. Pipe stiffness per ASTM D 2412, 46 psi.
3. PVC plastic meeting ASTM D 1784, Cell Classification 12364.
4. Integral bell and spigot joints with elastomeric seals complying with ASTM D 3212 and ASTM F 477.

**Reason for Revision:** Request from material supplier based on acceptance from ASTM.

**Comments:** None.

<b>Region:</b>	<input checked="" type="checkbox"/> Central	<input type="checkbox"/> East	<input type="checkbox"/> West
<b>Comments:</b>	Add language in execution (flexible pipe) stating anything over 36 inch needs to be specified or per manufacturer's requirements.		
<b>Action:</b>	<input type="checkbox"/> Deferred	<input type="checkbox"/> Not Approved	<input checked="" type="checkbox"/> Approved
<b>Region:</b>	<input type="checkbox"/> Central	<input checked="" type="checkbox"/> East	<input type="checkbox"/> West
<b>Comments:</b>	None.		
<b>Action:</b>	<input type="checkbox"/> Deferred	<input type="checkbox"/> Not Approved	<input checked="" type="checkbox"/> Approved
<b>Region:</b>	<input type="checkbox"/> Central	<input type="checkbox"/> East	<input checked="" type="checkbox"/> West
<b>Comments:</b>	None.		
<b>Action:</b>	<input type="checkbox"/> Deferred	<input type="checkbox"/> Not Approved	<input checked="" type="checkbox"/> Approved

**Final Regional Action Summary:** All 3 regions approved; see comments above.

**Board of Directors Action:** Approved.