

SUDAS Revision Submittal Form

Status Date: As of 5/20/2025 **Topic:** Pipe size for solid wall PVC pipe
Manual: Specifications **Manual Location:** Section 4010, 2.01, B

Requested Revision:

2.01 SANITARY SEWER (Gravity Mains)

...

B. Solid Wall Polyvinyl Chloride Pipe (PVC) 18 inch to ~~27~~ 48 inch:

1. Comply with ASTM F 679.
2. Pipe stiffness per ASTM D 2412, 46 psi.
3. PVC plastic meeting ASTM D 1784, Cell Classification 12454 or 12364.
4. Integral bell and spigot joints with elastomeric seals complying with ASTM D 3212 and ASTM F 477.

Reason for Revision: To be consistent with proposed revision to Solid Wall PVC.

Comments: None.

Region:	<input checked="" type="checkbox"/> Central	<input checked="" type="checkbox"/> East	<input checked="" type="checkbox"/> West
Comments:	None.		
Action:	<input type="checkbox"/> Deferred	<input type="checkbox"/> Not Approved	<input checked="" type="checkbox"/> Approved

Final Regional Action Summary: All 3 regions approved.

Board of Directors Action: Approved.