SUDAS Revision Submittal Form

Status Date:	As of 10/23/2026	**Topic:**	Class A concrete
Manual:	Specifications	**Manual Location:**	Section 7030, 2.01

Requested Revision:

2.01 PORTLAND CEMENT CONCRETE

A. Use Class ~~A or~~ C concrete ~~for sidewalks and driveways and Class C for shared use paths~~ with materials complying with Section 7010. Use coarse aggregate of Class 2 durability or better.

B. Comply with the following for PCC mixes ~~for sidewalks, shared use paths, and driveways~~ unless otherwise approved by the Engineer.

Table 7030.01: PCC Mixes

	Machine Finish	**Hand Finish**
Type of Concrete	Class ~~A or~~ C	Class ~~A or~~ C
Slump Minimum	1/2 in.	1/2 in.
Slump Maximum	2 1/2 in.	4 in.
Percent Air Content		
• Target	7%	7%
• Minimum	6%	6%
• Maximum	8 1/2%	8 1/2%

Reason for Revision: The industry states Class A concrete is not being used for sidewalks, driveways, or shared use paths.

Comments: Was also posed as a PWSB forum question and others stated it isn't used.

Region:	☒ Central	☒ East	☒ West
Comments:	None.		
Action:	☐ Deferred	☐ Not Approved	☒ Approved

Final Regional Action Summary: All 3 regions approved.

Board of Directors Action: